



NOTES:

1. THERE SHALL BE NO TAPS, PIPING BRANCHES, UNAPPROVED BYPASS PIPING, HYDRANTS, FIRE DEPT. CONNECTION POINTS, OR OTHER WATER-USING DEVICES CONNECTED TO THE SUPPLY LINE BETWEEN ANY WATER METER AND ITS DWI-REQUIRED BACKFLOW PREVENTER.
2. TANDEM BACKFLOWS REQUIRED IF SERVICE CANNOT BE INTERRUPTED.
3. REMOVEABLE INSULATED ENCLOSURE WITH FREEZE PROTECTION BY A 110 VOLT HEATER IS RECOMMENDED FOR ABOVE GROUND ASSEMBLIES.

<p>DAVIDSON WATER INC. WELCOME, NORTH CAROLINA BACKFLOW PREVENTION</p>
<p>BACKFLOW PREVENTION STANDARD DETAIL</p>
<p>DOUBLE CHECK VALVE ASSEMBLY (DC) 3/4-2" ABOVE GROUND</p>
<p>SCALE: NOT TO SCALE REVISED: 10/12/07</p>