



NOTES:

1. FOR 3/4" -1" ASSEMBLY, TWO CARSON/BROOKS (1324-12) BOXES REQUIRED. ONE CARSON/BROOKS COVER (1324-3PB) REQUIRED.
2. FOR 1-1/2" -2" ASSEMBLY, TWO CARSON/BROOKS (1730-18) BOXES REQUIRED. ONE CARSON/BROOKS COVER (1730-3PB) REQUIRED.
3. DRAIN TO ATMOSPHERE WHEN APPLICABLE.
4. INSTALLATION IN CONCRETE OR ASPHALT PROHIBITED.
5. INSTALLATION SUBJECT TO HEAVY MOWING OR VEHICLE TRAFFIC PROHIBITED.

<p><b>DAVIDSON WATER INC.</b>  <b>WELCOME, NORTH CAROLINA</b>  <b>BACKFLOW PREVENTION</b></p>
<p>BACKFLOW PREVENTION          STANDARD DETAIL</p>
<p>DOUBLE CHECK VALVE          ASSEMBLY (DC) 3/4"-2"          BELOW GROUND          NON TRAFFIC</p>
<p>SCALE: NOT TO SCALE          REVISED: 10/12/07</p>